

**DECISION TREE  
For Pressure Vessel Compliance  
OREGON PRESSURE VESSEL LAW**

Does not apply to or include the following if all listed exemptions are met:

- Fired water heaters for pools/spas (OAR 918-225-300)
- Refrigeration or air conditioning vessels (OAR 918-225-320)
- Piping components (OAR-918-225-340)
- Hot water storage tanks (OAR 918-225-350)
- Certain water storage vessels (OAR 918-225-360)
- Coil type boilers (Steam cleaners) (OAR 918-225-370)
- Refrigeration chillers-Waterside vessels (OAR 918-225-380)

For vessels encountered in other applications (storage, processing, etc.) use the following approach to determine requirements. If vessels are in a place of Public Assembly as defined in OAR 918-225-240(14), the requirements of ORS 480.525(1)(f) apply.

