

**State of Oregon
Building Codes Division**

Interpretive Ruling No. 00-3

PLUMBING PRODUCT APPROVAL REQUEST - BELCO MANUFACTURING, INC.

Initiated By: Belco Manufacturing, Inc.
13824 S.E. Steele St.
Portland, OR 97236
503-761-2118

REQUEST FOR RULING: Approval of the Belco Manufacturing's - 10 ga. 24" x 24" x 30", 10 ga. 24" x 24" x 38.5" w/4" or 6" or 8" outlet, 10 ga. 24" x 24" x 42" w/4" or 6" or 8" outlet, square & round Steel Catch Basins and 10 ga. 12" x 12" x 16" w 4" outlet, 10 ga. 18" x 18" x 26.5" w/4" outlet, 10 ga. 18" x 18" x 42.5" w/4" outlet steel area drains.

APPLICABLE CODE SECTION: 1996 Oregon State Plumbing Specialty Code, Section 1108.0.

FINDINGS: Effective April 1, 1996, the Division adopted plumbing code provisions listing the standards for catch basins in Section 1108.0. The Belco Manufacturing, Inc. 10 ga. square & round 24" x 24" x 30" Steel Catch Basins as submitted meets the provisions of Section 1108.0 of the 1996 Oregon State Plumbing Specialty Code. The additional catchbasins and area drains have been submitted to be included in this interpretive ruling by the manufacturer.

CONCLUSION: The State Plumbing Board recommends the Building Codes Administrator approve Interpretive Ruling No. 00-3.

Lewis E. Seagraves, Chairman
State Plumbing Board

Date

The recommendations and findings of the Board are accepted and Interpretive Ruling No. 00-3 is approved.

Joseph A. Brewer III, Administrator
Building Codes Division

Date