



*Working with Oregonians  
to ensure safe building  
construction while  
supporting a positive  
business climate.*

November 29, 2005

**No: 2005 ORSC Section P2910.6 and Table  
P2910.2  
2005 Oregon Residential Specialty Code**

**Subject:** Water Pipe Sizing For Wells And Pressure Reducing Valves

**Code Section:** Section P2910.6 & Table P2910.2

**Code Edition:** 2005 Oregon Residential Specialty Code

**Date:** November 22, 2005

**Question:** When sizing water supply systems per section P2910.6 and Table P2910.2, is the pressure tank or pressure reducing valve considered the source of supply?

**Answer:** Yes, the developed length of the water supply piping would be measured beginning at the outlet of the well pressure tank, or at the outlet of the pressure reducing valve if used.

Note: See 2005 OPSC Interpretation Section 610.8 & Table 6-5.

**Contact:** Terry Swisher, Chief Plumbing Inspector  
[terry.l.swisher@state.or.us](mailto:terry.l.swisher@state.or.us)  
(503) 373-7488

