

**BUILDING CODES DIVISION RULING ON ACCEPTABILITY OF  
MATERIAL, DESIGN OR METHOD OF CONSTRUCTION  
RULING NO. 95-5**

**Initiated By:** TED JOHNSON SR.  
MIDWAY EQUIPMENT AND SUPPLY  
P.O. BOX 667  
PRINEVILLE OR 97754

**RE: PLUMBING PRODUCT APPROVAL REQUEST—MIDWAY EQUIPMENT AND SUPPLY  
REQUEST**

Approval of catch basin, area drain, sand interceptor and trough drain.

**APPLICABLE CODE SECTIONS OR STANDARDS**

1992 Oregon State Plumbing Specialty Code (OSPSC), Chapter 1, Sections 102(i), 104(a) and Chapter 14, Sections 1408(a) through (e).

**TECHNICAL AND SCIENTIFIC FACTS**

Information submitted by the manufacturer, including engineered drawings, material specifications and HS20-4 AASHTO load calculations, show these products are manufactured in a manner and of a material meeting the standards adopted in the OSPSC.

**FINDING**

Due to the above technical and scientific facts the Plumbing Board finds the materials and construction of the Midway Equipment and Supply Company's 24-inch × 24-inch × 36-inch catch basin, 16-inch × 16-inch × 24-inch area drain, 12-inch × 111-inch trough drain and 24-inch × 48-inch × 36-inch sand interceptor meet the standards prescribed in the OSPSC in quality, strength, effectiveness, durability and safety.

\_\_\_\_\_  
(signed April 21, 1995)

Harry C. Reeder, Chairman  
Plumbing Board

\_\_\_\_\_  
Date

**RULING**

After consideration of the standards and interpretations of the International Association of Plumbing and Mechanical Officials and the findings of the Plumbing Board this ruling is adopted as stated.

\_\_\_\_\_  
(signed April 24, 1995)

Joseph A. Brewer III, Administrator  
Building Codes Division

\_\_\_\_\_  
Date